Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. Dated:

It is certified that an inspection team headed by Dr. N.K. Singh (Supretendent).

(Name of Officers with designation) from Public Health Department PHED

inspected the P.S. Public School (Jamapur: Karimabad. Ghazipur)

(Name & Address of the school) on 13.05.25 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 0525-015/016 dated 06/05/25

of Era Chemical Testing & Research (PHED Lab) certified that the

P.S. Public School laboratory. (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till One year (12.05.2026). N Singh 4/05/25

Signature with Seal:

Name DR N.K. SINGH

Designation Superintendent

Name & Address of the Office / Department:

To P.S. Public School.
Jamapur. Karimabad. Ghazipur.
(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

ERA CHEMICAL TESTING & RESEARCH LABORATORY

Harahua Babatpur road Varanasi 221105 email-erachen1105@gmail.com

TEST REPORT

Type of testing : *Drinking Water*

Sample site : *Prabhu Narayan Singh School Kasimabad Ghazipur Uttar Pradesh*

Test order date	: 30/ 04 /2025	Reporting date	: 06/05/2025
Number of sample	: 02	Sample id no.	: 0525- 015/016
Sampling collection site	: Drinking water tap/ Kitchen tap	Mode of collection	: by agency
Packing and marking	: Same day at site	Period of testing and analysis	: 148 hr.

Chemical Result

S.No.	Test parameter	Result	Acceptable limit	Unit
1	Colour	BDL(DL 5)	15	Colour unit
2	pH	7.2	6.8-7.8	-
3	Test	agreeable		-
4	Calcium (Ca)	46	40-175	mg/l
5	Chloride(Cl)	14.5	< 250	mg/l
I6	Iron (Fe)	0.6	0.1-1.0	mg/l
7	Total alkalinity	128	<200	mg/l
8	Total hardness	146	<200	mg/l
9	Magnesium (Mg)	6	<100	mg/l
10	Nitrate (NO3)	0.6	<45	mg/l

Biological Test Result

S .No.	Test Parameter	Result	Acceptable limit	unit
1	Total coli form	Absent	Absent	As/SI
2	E. Coli.	Absent	Absent	As/SI

End of Report

Dr . Prateek Ghosh
Checked by - QA

Dr. Rasmika divyankar
Authorised Signatory- Biological

Dr. Vibhav sachan
Authorised Signatory- Chemical